

# WALDEN'S RIDGE UTILITY DISTRICT

3900 Taft Highway  
Signal Mountain, Tennessee 37377

Commissioners:

FRANK M. GROVES, JR., PRESIDENT  
J. ROBERT MCKENZIE, VICE PRESIDENT  
DAVID J. FULTON, SECRETARY

General Manager:  
RONALD WEST

## SERVICE LINE POLICY - AMENDED


For any new construction, the service line will be of **COPPER** or **BLUE PEX WITH BRASS FITTINGS** (*GRADE A CROSS-LINKED POLYETHYLENE WITH ULTRA VIOLET PROTECTION, MUST BE BLUE COLOR*) from the meter to the dwelling. The District will inspect the service line prior to installing the meter allowing the service to become active.

*The only exception the District will allow is if the property owner had ownership of the property prior to March 27, 2007 and signs a waiver relinquishing any right to a leak adjustment on the service line per the District's Leak Adjustment Policy, then the property owner may use their choice of material to install the service line from the meter to the dwelling.*

For any customer requesting a leak adjustment for their service line from the meter to the dwelling per the Leak Adjustment Policy, the customer will be granted one (1) adjustment per policy.

However, once this adjustment is given, COPPER OR BLUE PEX MUST BE INSTALLED BEFORE ANOTHER LEAK ADJUSTMENT WILL BE GIVEN ON THE SERVICE LINE PER POLICY. When the service line is replaced, the customer must notify the District for a service line inspection before the customer will qualify for another leak adjustment.

**EFFECTIVE: 29 SEPTEMBER 2008**

  
\_\_\_\_\_  
Frank M. Groves, Jr., President

29 September 2009  
\_\_\_\_\_  
Date

  
\_\_\_\_\_  
J. Robert McKenzie, Vice President

29 September 2009  
\_\_\_\_\_  
Date

\_\_\_\_\_  
David J. Fulton, Secretary

29 September 2009  
\_\_\_\_\_  
Date

(423) 886-2683 Office . (423) 886-1940 Fax  
Office Hours: 8:00 a.m. – 4:30 p.m. Monday through Friday